



SHIFTING THE LIMITS

Wels, August 25th 2014

DC CURRENT FRONIUS SYMO 3.0-3-S – 20.0-3-M

Fronius International GmbH

hereby certifies that the inverters

/ **Fronius Symo 3.0-3-S – 20.0-3-M**

do inject a DC current of $< 0,5\%$ of the nominal output current into the grid.

Fronius International GmbH

Solar Energy Division
Froniusplatz 1
A-4600 Wels

A handwritten signature in blue ink, appearing to read "ppa Martin Hackl".

Ing. Prok. Martin Hackl
Head of Solar Energy Division